Eighth Semester B.E. Degree Examination, Dec.2017/Jan.2018 Power System Operation & Control

Time: 3 hrs.

Max. Marks:100

Note: Answer FIVE full questions, selecting at least TWO questions from each part.

PART - A

a. Discuss different states of power system with neat sketch.

(05 Marks)

b. Derive an expression for Tie-Line power and frequency deviation for two area system.

(05 Marks)

- c. Two synchronous Generators are initially supplying a common load at 1.0 p.u and frequency of 50 Hz. The rating of unit 1 is 337 MW and has 0.03 plu droop built into its governor unit 2 is rated at 420 MW and has 0.05 p.u. droop. Find each unit share of 10% increase in load demand. Also find new-value of Line frequency. Assume free governor action. (10 Marks)
- 2 a. For two generators operating in parallel deduce,

$$R_{\text{system}} = \frac{1}{\frac{P_1 \text{rate}}{R_1} + \frac{P_2 \text{rate}}{R_2}} \frac{1}{\text{MW}}$$

Where R_1 and R_2 are droop characteristics of Generator 1 and Generator 2. (08 Marks)

- b. With a neat block diagram, explain (i) Load model (ii) Generator model. (06 Marks)
- c. Explain (i) Automatic generator control (ii) Area control error. (06 Marks)
- 3 a. With a block diagram, list the functions of, (i) AVR (ii) ALFC loops. (05 Marks)
 - b. Determine the primary ALFC loop parameters for control area having the following data:
 - (i) Rated capacity of area $\neq 2000 \text{ MW}$ (ii) Frequency $\equiv 50 \text{ Hz}$
 - (iii) Inertia constant = 5.0 (iv) Operating load (Pp) \neq 1000 MW (05 Marks)
 - c. A single area consist of two generators with following parameters:

Generator -1 = 1200 MVA, R = 6% (on machine base)

Generator -2 = 1000 MVA, R = 4%, (on machine base)

The units are sharing 1800 MW at nominal frequency of 50 Hz. Unit-1 supplies 1000 MW and unit 2 supplies 800 MW. The system load is increased by 200 MW. Find (i) Steady state frequency and generation of each unit if D = 0. (ii) Repeat (i) if D = 1.5

Assume a base of 2000 MVA. (10 Marks)

- 4 a. Explain different sources of reactive power generation and absorption of reactive power in a power system. (05 Marks)
 - b. Deduce a equation relating voltage, power and reactive power at node.

(05 Marks)

c. A 220 KV, line has tap changing transformer at both ends. The transformer at sending end has a nominal ratio of 11/220 KV and that at receiving end 220/11 KV. The line impedance is $20 + j60\Omega$ and the load at the receiving end is 100 MVA, 0.8 γ .f (lag). If the product of two off-nominal tap setting is 1, find the tap-setting to give 11 KV at load Bus. (10 Marks)

PART - B

- 5 a. Explain in detail constraints in unit commitment problems. (10 Marks)
 - b. With a neat flow-chart, explain forward dynamic programming method of solving u.c. problem. (10 Marks)

10EE82

6 a. What is meant by power system security? Explain major functions involved in system security. What are the factors affecting system security? (10 Marks)

b. With the help of flow-chart, explain contingency analysis.

(10 Marks)

7 a. Explain Energy Management System'.

(10 Marks)

b. Derive the steady-state reliability expression and general reliability expression.

(10 Marks)

Write short notes on: (any four)

a. u.c. problem.

b. Least square estimation.

c. Spinning reserve.

d. B-coefficients.

e. Network sensitivity factors

(20 Marks)