

CBCS SCHEME

Modified

USN

--	--	--	--	--	--	--	--	--	--	--

17EE553

Fifth Semester B.E. Degree Examination, Dec.2019/Jan.2020 Electrical Estimation and Costing

Time: 3 hrs.

Max. Marks: 100

Note: Answer FIVE full questions, choosing ONE full question from each module.

Module-1

- 1 a. Define estimating and state its purpose. State the important facts which an estimator should know for preparing an internal wiring estimate. (08 Marks)
- b. Explain the following : (i) Catalogues (ii) Purchase system (iii) Contingencies. (06 Marks)
- c. Mention the different mode of tendering and explain them. (06 Marks)

OR

- 2 a. State the purpose of IE rule and regulations. Explain IE rules 29,30 and 55. (08 Marks)
- b. Write note on the comparative statement. (06 Marks)
- c. Explain (i) Overhead charges (ii) Profit (iii) Payment of bills. (06 Marks)

Module-2

- 3 a. List the general rules guidelines for residential installation. (04 Marks)
- b. Explain the different systems of distribution of energy in a building. (04 Marks)
- c. Draw the electrical circuit and estimate the quantity of material required for the wiring system. Chosen in a house plan shown in Fig. Q3 (c). The height of ceiling as 3.6 m and one plug point (60 W) has to be provided in each room. (12 Marks)




Fig. Q3 (c)

OR

- 4 a. Explain the points on which the choice of wiring system can be made. Why fuse is connected in the phase wire? (08 Marks)
- b. With reference to internal electrification of building, explain how to determine the following: (i) Total load (ii) Rating of main switch and distribution board (iii) Number of circuits. (06 Marks)
- c. Determine the size of conductor (copper) for a 2-core cable required to carry a maximum current of 60 A. Length of the cable used is 60 m and declared supply voltage is 240 V AC. (Current ratings of cables shown in table Q4 (c) may be referred) (06 Marks)

Size of cable		Current rating in Amps		Approximate Ampere-meter per volt drop
No. and dia of wire	Area in mm ²	2 Core cable	3 or 4 core cable	
19 / 1.12	19.35	62	50	1050
19 / 1.32	25.80	74	59	1475
19 / 1.626	38.70	97	78	2200

Table Q4 (c)

Important Note : 1. On completing your answers, compulsorily draw diagonal cross lines on the remaining blank pages.
2. Any revealing of identification, appeal to evaluator and/or equations written eg, 42+8 = 50, will be treated as malpractice.

Module-3

- 5 a. State the important considerations regarding motor installation wiring. (06 Marks)
 b. Explain the determination of input power, size of conduit, distribution board, main switch, starter size of the cable and rating of the fuse. (08 Marks)
 c. Prepare an estimation of materials for providing OH service connection to a single storied building with 240 V, 1 ϕ , 50 Hz AC supply. The building has a light and fan load of 5 kW. The supply is to be given from an OH line 20 m away from the building. (assume missing data). (06 Marks)

OR

- 6 a. What do you understand by service line? Write down the various methods of installing service lines. (04 Marks)
 b. With simple sketches, explain any two methods of installation of OH service lines based on the prevailing conditions of the building. (06 Marks)
 c. A 10 HP, 415 V, 3 ϕ , 50 Hz induction motor is to be installed in a workshop the plan of which is shown in Fig. Q6 (c). Show the single line diagram and estimate the quantity of material required. (10 Marks)




Fig. Q6 (c)

Module-4

- 7 a. List out the various points to be considered at the time of erection of over head lines. (06 Marks)
 b. Explain the following : (i) Cross arms (ii) Guys and stays (iii) Lightning arrestor. (06 Marks)
 c. Explain the necessity of earthing of transmission line supports and also show with a neat sketch how earthing of a line support is done using pipe earthing. (08 Marks)

OR

- 8 a. Explain what is meant by repairing and jointing of overhead ACSR transmission conductors. How repairing or jointing is done? (06 Marks)
 b. Explain the functions of the following in relevance to OH transmission and distribution : (i) Phase plates (ii) Beads of jumpers. (06 Marks)
 c. A pole for an overhead 11 KV, 3 ϕ , 50 Hz line is required to be earthed and a stay is to be provided make a neat sketch, how it should be done. Prepare a list of materials required. (08 Marks)

Module-5

- 9 a. Describe briefly the equipment that must be available in a substation. (05 Marks)
 b. Write short notes on substation auxiliary supply. (05 Marks)
 c. Prepare a list of material required for the installation of a 400 KVA indoor type 11/0.433 KV transformer. (10 Marks)

OR

- 10 a. Explain the functions of the following in a substation : (i) Isolators (ii) Earthing switch (iii) Batteries. (06 Marks)
 b. Draw the single line diagram for 132/33 KV substation with main and transfer bus having 2 \times 40 MVA transformers. Prepare an estimation of materials required, with their complete specification. (08 Marks)
 c. Explain the purposes of substation earthing system. (06 Marks)

Modifications in the scheme and solution

1 message

Dr. A.Manjunath <manjuprinci@gmail.com>
To: pmanjunath p <pmanjunathvtu@gmail.com>

Wed, Jan 8, 2020 at 5:05 PM


Modifications in the scheme and solution of subject 17EE553 Electrical Estimation and costing.

Q.3.c.Considering length of the building as 8.4mtrs
as per Scheme and solution

Q.6.c.Considering length of workshop as 30mtrs
Length of the earth wire required is 70mtrs or 7kg's

Dr.A.Manjunatha

" APPROVED "



Registrar (Evaluation)

Visvesvaraya Technological University
BELAGAVI - 590018



Signature of Scrutinizer

06/11/19

Scheme & Solution

Subject Title : Electrical Estimation & Costing Subject Code : 17EE553

Question Number	Solution Module - 1	Marks Allocated
1. (a)	<p><u>Estimating</u> is an act of assessment of quantities of different items and cost thereof to plan the amount required for executing a work before actually carrying out the work.</p> <p><u>Purpose of estimating</u> : * It becomes necessary to prepare a complete project for the given programme</p> <p>* It is essential to provide us an accurate assessment of the amount of money required, availability of material etc.</p> <p>* It is used to know about the material required with complete specifications and quantity of each item and the cost to be incurred thereon before taking up any new programme in hand.</p> <p><u>The following facts to the estimate should be known to an estimator for preparing an internal wiring estimator:</u></p> <ul style="list-style-type: none"> * Complete specifications, giving the general scheme of the installation, type of wiring to be adopted and type and quality of materials to be used it. * Complete schedule of the pts to be wired for with their switches and fittings or alternatively details of whatever else relating to the estimate. * Plans & sections marked with details, at least with the positions of main switchgear and distribution boards. 	<p>— 2 m</p> <p>— 3 m</p> <p>— 3 m</p> <p>— 6 m</p>
1. (b)	each term x 2 m	
1. (c)	<p><u>Modes of Tendering</u></p> <p>open tendering, global tendering, limited tendering, single tendering, proprietary tendering + spot tendering</p> <p>Explanation of them</p>	<p>— 1 m</p> <p>— 5 m</p>
2. (a)	<p><u>Purpose of IE rule & regulations</u></p> <ul style="list-style-type: none"> * safeguard consumers of electrical energy from shock * minimise fire risk * ensure as far as possible, satisfactory operation of equipment and apparatus used <p>IE Rule 29: construction, installation, protection, operation and maintenance of electric supply lines and apparatus — 2 m</p> <p>IE Rule 30: Service lines & apparatus on consumers premises — 2 m</p> <p>IE Rule 55: Declared frequency of supply to consumer — 2 m</p>	<p>— 2 m</p> <p>— 2 m</p> <p>— 2 m</p>

Question Number	Solution	Marks Allocated																																																																					
2.(b)	<p>Theory explanation of Comparative statement Format - II - Comparative price statement</p> <p>1. No. of enquiries issued: _____ Enquiry NO: _____ 2. No. of tenders received: _____ Date: _____ 3. Date of opening of tender: _____ Due date: _____</p> <table border="1" data-bbox="272 526 1323 880"> <thead> <tr> <th rowspan="2">Item No.</th> <th rowspan="2">Description</th> <th rowspan="2">Quantity Received</th> <th colspan="3">Previous purchase</th> <th rowspan="2">1</th> <th rowspan="2">2</th> <th rowspan="2">3</th> <th rowspan="2">4</th> <th rowspan="2">5</th> </tr> <tr> <th>order NO.</th> <th>date</th> <th>unit Price</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table> <p>Sales Tax Excise Duty Discount Is the offer in conformity with our requirements (yes/no) Validity for acceptance Prices quoted (Firm/variable) Prices quoted EX-WORKS/F.O.B/FAS/C & FCIF etc Condition of the material offered (factory new union surplus etc) Delivery offered weeks/Days/months A.R.D) Terms of Payment L/C/DOCS through Bank/ Advance etc Local candidates if any/agency commission</p>	Item No.	Description	Quantity Received	Previous purchase			1	2	3	4	5	order NO.	date	unit Price																																																								<p>(2) m</p> <p>(4) m</p>
Item No.	Description				Quantity Received	Previous purchase							1	2	3	4	5																																																						
		order NO.	date	unit Price																																																																			
2.(c)	<p>Explanation of each term x (2) m</p>	<p>(6) m</p>																																																																					
<p><u>Module - 2</u></p>																																																																							
3.(a)	<p>Any 5 general rules guide lines for residential installation</p>	<p>(4) m</p>																																																																					
3.(b)	<p>different s/m's of distn of energy in a building ↳ Distribution Board s/m & Tree s/m Explanation of each s/m x (2) m</p>	<p>(4) m</p>																																																																					

Question Number	Solution	Marks Allocated
3.(C)	<p>The solution consists of three main parts:</p> <ul style="list-style-type: none"> Floor Plan: Shows a room (3.6m x 2.7m) and a hall (4.8m x 4.8m) with a veranda (3.6m x 2.1m). Dimensions are clearly marked. Circuit Diagram: A schematic showing a main switch (MB), a fuse (F), and two sub-circuits (SB1 and SB2). SB1 controls lights L1, L2, L3, and L4. SB2 controls lights L5 and L4. A fuse (F) is placed on the phase wire before the sub-circuits. Wiring Plan: Shows the physical layout of wires connecting the lights and switches to the main board. It specifies the use of 1.5mm² Aluminium Conductor, 650V grade PVC cable. The main board is a DPIC Switch (240V, 16A). <p>Legend:</p> <ul style="list-style-type: none"> Thick solid line: Earth wire Thin solid line: Phase wire Dashed line: Neutral wire Dotted line: Half wire 	<p>Marks Allocated</p> <p>① m</p> <p>② m</p>

Question Number	Solution	Marks Allocated
	<p>No. of light pts = 5; No. of fan pts = 1; No. of plug pts = 2 ∴ Connected load = $8 \times 60 \text{ W} = 480 \text{ W}$; so one ckt used, no distr. Board. Full load current, $I = \frac{480}{240} = 2 \text{ A}$. Hence 240V, 16A, DPIC switch fuse used as a main switch & 1/1.40 mm aluminium cond, single core, 650V grade, PVC cable having current carrying capacity of 10A and cond. area 1.5 mm^2.</p>	<p>①m</p>
	<p>Assumptions: Height of casing-capping run = 3m Height of bracket light pts = 2.4m Height of main board & switch board = 1.5m The distance of meter board (MB) from front wall (in hall) = 0.2m</p>	<p>①m</p>
	<p>Length of PVC casing capping: From meter board to main board = 0.2m From meter board to switch board SB₁ = 5m Vertical run to ceiling in hall (above SB₁) = 0.6m Run along ceiling in hall = 7.2m Drop from ceiling to L₁ = 1.2m Drop from ceiling to L₂ = 1.2m From switch board SB₂ to L₄ = 4.2m Vertical run to ceiling in room = 0.6m Run along ceiling in room = 2.7m Drop from ceiling to lamp L₃ = 1.2m Total length of PVC casing capping = 24.1m wastage & length used in joints (15%) = 3.6m (say) ∴ Total = 27.7m ≈ 28m (say)</p>	<p>①m</p>
	<p>Length of Conduit of 19mm size: Connections taken from SB₁ to SB₂ and from light pt L₄ to L₅ through 19mm Conduit. Hence total length of conduit = 0.5m</p>	<p>①m</p>
	<p>Length of Phase wire: From meter board to main board = 0.2m = 5m From main board to switch board SB₁ = 5m From SB₁ to fan pt. = 4.5m; From SB₁ to SB₂ = 0.25m From SB₁ to L₁ = 8.1m; From SB₁ to L₂ = 8.1m; From SB₂ to L₄ = 4.2m; From SB₂ to L₅ = 4.45m From SB₂ to L₃ = 8.1m; Total = 42.9m wastage & extra wire at distr. board = 8.6m ∴ Total length = 51.5m</p>	<p>①m</p>
	<p>Length of Neutral wire: From meter board to main board = 0.2m From main board to F = 6.5m; From F to L₁ = 3.6m; From L₁ to L₂ = 7.2m</p>	<p>①m</p>


Question Number	Solution	Marks Allocated																																																																																														
	<p>From L_2 to $SB_1 = 8.1\text{m}$; From SB_1 to $SB_2 = 0.25\text{m}$ From SB_2 to $L_4 = 4.2\text{m}$; From L_4 to $L_5 = 0.25\text{m}$ From L_5 to $L_3 = 5.35$; Total = 35.65m Wastage & length used in connections (10%) = 3.6m Total length = 39.25m</p> <p>Total length of Al cond, single core, PVC cable of size 1.5mm^2 (Phase + neutral) = $90.75\text{m} = 90\text{m}$ (say) Length of earth wire : (14 SWG, GI wire)</p> <p>From meter board to main board = 0.2m From main board to $SB_1 = 5\text{m}$; From SB_1 to $SB_2 = 0.25\text{m}$ Total length including wastage = $6\text{m} = 0.2\text{kg}$ (say)</p> <p>Estimate on the basis of item wise rates :</p>	①m																																																																																														
	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2" style="width: 5%;">Sl. No</th> <th rowspan="2" style="width: 65%;">Description of material with full specifications.</th> <th colspan="2" style="width: 30%;">Quantity Required</th> </tr> <tr> <th style="width: 10%;">Qty</th> <th style="width: 20%;">Unit</th> </tr> </thead> <tbody> <tr><td>1.</td><td>240V grade, 16A, DPIC switch with fuse and neutral link</td><td>1</td><td>NO.</td></tr> <tr><td>2</td><td>PVC casing capping 76mm x 25mm</td><td>28</td><td>m</td></tr> <tr><td>3</td><td>14 SWG, GI wire (earth wire)</td><td>0.2</td><td>kg</td></tr> <tr><td>4</td><td>Earthing thimbles with nuts and bolts</td><td>3</td><td>NOS</td></tr> <tr><td>5</td><td>1.5mm^2 single core 650V grade aluminium conductor PVC cable</td><td>90</td><td>m</td></tr> <tr><td>6</td><td>piano switches, oneway 5A surface type</td><td>8</td><td>NOS</td></tr> <tr><td>7</td><td>Ceiling Rose, two plate PVC type</td><td>1</td><td>NO.</td></tr> <tr><td>8</td><td>Brass brackets with holders</td><td>4</td><td>NOS</td></tr> <tr><td>9</td><td>Watertight bracket with holder & globe</td><td>1</td><td>NO.</td></tr> <tr><td>10</td><td>plug sockets 3 pin 5A</td><td>2</td><td>NOS</td></tr> <tr><td>11</td><td>Teak wood boards (double): 25cm x 20cm</td><td>2</td><td>do</td></tr> <tr><td>12</td><td>Round wooden blocks 20cm x 15cm</td><td>1</td><td>do</td></tr> <tr><td>13</td><td>Teak wood gutties 10cm x 4cm</td><td>6</td><td>do</td></tr> <tr><td>14</td><td>wooden screws : 51mm for boards</td><td>100</td><td>do</td></tr> <tr><td></td><td>32mm for casing</td><td>18</td><td>NOS</td></tr> <tr><td></td><td>13mm for capping</td><td>45</td><td>do</td></tr> <tr><td></td><td>19mm for switches</td><td>180</td><td>do</td></tr> <tr><td>15</td><td>Cement, sand, paint, varnish etc</td><td>32</td><td>do</td></tr> <tr><td></td><td>Labour cost @ Rs 60 per point</td><td></td><td>Total</td></tr> <tr><td></td><td>Contingencies 5%</td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td>Grand Total</td></tr> <tr><td></td><td></td><td></td><td>Say</td></tr> </tbody> </table>	Sl. No	Description of material with full specifications.	Quantity Required		Qty	Unit	1.	240V grade, 16A, DPIC switch with fuse and neutral link	1	NO.	2	PVC casing capping 76mm x 25mm	28	m	3	14 SWG, GI wire (earth wire)	0.2	kg	4	Earthing thimbles with nuts and bolts	3	NOS	5	1.5mm^2 single core 650V grade aluminium conductor PVC cable	90	m	6	piano switches, oneway 5A surface type	8	NOS	7	Ceiling Rose, two plate PVC type	1	NO.	8	Brass brackets with holders	4	NOS	9	Watertight bracket with holder & globe	1	NO.	10	plug sockets 3 pin 5A	2	NOS	11	Teak wood boards (double): 25cm x 20cm	2	do	12	Round wooden blocks 20cm x 15cm	1	do	13	Teak wood gutties 10cm x 4cm	6	do	14	wooden screws : 51mm for boards	100	do		32mm for casing	18	NOS		13mm for capping	45	do		19mm for switches	180	do	15	Cement, sand, paint, varnish etc	32	do		Labour cost @ Rs 60 per point		Total		Contingencies 5%						Grand Total				Say	②m
Sl. No	Description of material with full specifications.			Quantity Required																																																																																												
		Qty	Unit																																																																																													
1.	240V grade, 16A, DPIC switch with fuse and neutral link	1	NO.																																																																																													
2	PVC casing capping 76mm x 25mm	28	m																																																																																													
3	14 SWG, GI wire (earth wire)	0.2	kg																																																																																													
4	Earthing thimbles with nuts and bolts	3	NOS																																																																																													
5	1.5mm^2 single core 650V grade aluminium conductor PVC cable	90	m																																																																																													
6	piano switches, oneway 5A surface type	8	NOS																																																																																													
7	Ceiling Rose, two plate PVC type	1	NO.																																																																																													
8	Brass brackets with holders	4	NOS																																																																																													
9	Watertight bracket with holder & globe	1	NO.																																																																																													
10	plug sockets 3 pin 5A	2	NOS																																																																																													
11	Teak wood boards (double): 25cm x 20cm	2	do																																																																																													
12	Round wooden blocks 20cm x 15cm	1	do																																																																																													
13	Teak wood gutties 10cm x 4cm	6	do																																																																																													
14	wooden screws : 51mm for boards	100	do																																																																																													
	32mm for casing	18	NOS																																																																																													
	13mm for capping	45	do																																																																																													
	19mm for switches	180	do																																																																																													
15	Cement, sand, paint, varnish etc	32	do																																																																																													
	Labour cost @ Rs 60 per point		Total																																																																																													
	Contingencies 5%																																																																																															
			Grand Total																																																																																													
			Say																																																																																													

Question Number	Solution	Marks Allocated
<u>Estimate on the basis of supply / fixing rates</u>		
Sl. NO	Description of material with full specifications	Qty Required Qty Unit
1	Supply & fixing of 240V, 16A, DPIC switch with fuse & neutral link on board complete in all respects Supply Rates Fixing Rates	1 NO.
2	Supply & fixing of PVC casing capping 76mm x 25mm Supply Rates Fixing Rates	28 m
3	Wiring of pts in 1.5 mm ² PVC insulated single core aluminium cond cable drawn through casing capping and 5A flush type switches with 3mm bakelite sheet with brass screws & washers. Supply Rates Fixing Rates	5 NOS.
4	As in item NO. 3 above but for ceiling fans with earth wire of same size Supply Rates Fixing Rates	1 NO.
5	As in item NO. 4 above but for plug pts with 5A flush type switches & earth wire of same size Supply Rates Fixing Rates	2 NOS
6	Water-tight bracket with holder and globe Supply Rates Fixing Rates	1 NO.
Total → Contingencies 5% → Grand Total → say →		
4. (a)	<u>choice of wiring slms</u> ↳ safety, durability, Appearance, Mechanical Protection, permanency, Accessibility, Initial cost, Maintenance Cost Explanation of each term purpose of Fuse connected in phase wire	} — 1m } — 5m } — 2m
4. (b)	<u>For determination of total load</u> → Ratings of light pts, Fan pts, socket outlets, power socket outlets & exhaust fans pt may be assumed or known or specified.	} — 2m

Question Number	Solution	Marks Allocated
	<p>The Determination of no of sub. cpts decided as per no of pts to be wired & total load to be connected to the supply systems. The no of pts determined as per size of room, illumination level required & luminous efficiency of lamps to be used</p> <p>Determination of ratings of main switch & disto board</p>	<p>} (2) m</p>
	<p>The current rating of main switch is decided as per total current of the ckt to be controlled by it.</p> <p>The current rating of disto board is decided as per no of sub-cpts to be connected to it & current of sub-ckt having highest current rating.</p>	<p>} (1) m</p> <p>} (1) m</p>
<p>4.(c)</p>	<p>Total ampere - metres in the ckt = max. current of the ckt x length of ckt cable (lead & return) = $60 \times 120 = 7200$ ampere - metre</p> <p>Permissible v/g drop = $\frac{2}{100} \times 240 + 1 = 5.8$ V</p> <p>Ampere - metres per volt of permissible drop = $\frac{\text{Total ampere - metres in the ckt}}{\text{Permissible v/g drop}} = \frac{7200}{5.8} = 1240$</p> <p>From the table, copper cond. cable having v/g drop of fig. next to fig. of ampere-metres per volt drop, determined above, is 19/1.32 mm having current carrying capacity of 74 amperes and giving 1 volt drop per 1475 ampere-metres.</p> <p>Since the current carrying capacity of copper cond. cable of size 19/1.32 mm selected is 74 A, more than ckt max. current of 60 A, & v/g drop caused by this cable will be equal to $\frac{7200}{1475} = 4.88$ volts, less than permissible v/g drop of 5.8 volts, hence selected.</p>	<p>} (1) m</p> <p>_____ (1) m</p> <p>} (1) m</p> <p>} (1 1/2) m</p> <p>} (1 1/2) m</p>
	<p><u>Module - 3</u></p>	
<p>5.(a)</p>	<p>Any 6 pts → important considerations regarding motor installation wiring</p>	<p>_____ (6) m</p>
<p>5.(b)</p>	<p>Input to the motor in watts = $\frac{\text{o/p in watts}}{\text{Motor efficiency}}$</p> <p>= $\frac{\text{Rated BHP} \times 735.5}{\eta_m}$ Since 1 HP (metric) = 735.5 watts</p>	<p>} _____ (1) m</p>

Question Number	Solution	Marks Allocated																						
	<p>The size of conduit is determined from the table of max. capacity of conduits for drawing-in of 1100V grade cables. -1m</p> <p>V/g & current rating of distn board is decided from the no of ckt to be fed from it, v/g rating of ckt & starting current of sub-ckt having highest current rating respectively. -1m</p> <p>The current rating of main switch is decided as capable of handling starting current of one motor (of highest rating) plus full load current of remaining motors to be controlled from it. -1m</p> <p>For starting of squirrel cage IMs of capacity upto 0.75 kW, b/w 0.7 kW & 1 kW & above 1 kW, DOL starter, Y-Δ starter and auto T/F starter respectively are used. -1m</p> <p>For starting of slip ring IMs of high ratings, rotor resistance starter is used. -1m</p> <p>The size of cable is determined as per full load current of the motor. -1m</p> <p>The rating of fuse should be based upon the motor starting current & cable current rating should not be lower than half of fuse current rating. -1m</p>																							
5. (c)	<p>Taking diversity factor as 1.66</p> <p>Total load requirement = $\frac{5000}{1.66} = 3000 \text{ W}$</p> <p>Let future load be twice of present load.</p> <p>i.e. $2 \times 3000 \text{ W} = 6000 \text{ W}$</p> <p>Load current in Amps = $\frac{\text{Load in Watts}}{\text{Rated V/g}} = \frac{6000}{240} = 25 \text{ A}$</p> <p>Hence twin core 1/3.55 mm or 10 mm² aluminium cond weather proof cable having a current carrying capacity of 34 A may be employed. -2m</p>																							
	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2" style="width:5%;">Sl. NO</th> <th rowspan="2" style="width:65%;">Description of materials with complete specifications.</th> <th colspan="2" style="width:30%;">Qty Required</th> </tr> <tr> <th style="width:15%;">Qty</th> <th style="width:15%;">Unit</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td>10 mm², 650V, twin core, aluminium cond. weather proof cable</td> <td>40</td> <td>m</td> </tr> <tr> <td>2.</td> <td>8 SWG GI wire (earth wire)</td> <td>4</td> <td>Kg</td> </tr> <tr> <td>3.</td> <td>GI pipe 50 mm dia</td> <td>4</td> <td>m</td> </tr> <tr> <td>4.</td> <td>HG conduit 16 SWG, 25 mm dia</td> <td>4</td> <td>do</td> </tr> </tbody> </table>	Sl. NO	Description of materials with complete specifications.	Qty Required		Qty	Unit	1.	10 mm ² , 650V, twin core, aluminium cond. weather proof cable	40	m	2.	8 SWG GI wire (earth wire)	4	Kg	3.	GI pipe 50 mm dia	4	m	4.	HG conduit 16 SWG, 25 mm dia	4	do	
Sl. NO	Description of materials with complete specifications.			Qty Required																				
		Qty	Unit																					
1.	10 mm ² , 650V, twin core, aluminium cond. weather proof cable	40	m																					
2.	8 SWG GI wire (earth wire)	4	Kg																					
3.	GI pipe 50 mm dia	4	m																					
4.	HG conduit 16 SWG, 25 mm dia	4	do																					

Question Number	Solution		Marks Allocated
5	pole clamp	1	No.
6	pipe clamps	2	do
7	GI thimbles	3	do
8	Wooden bushes for GI pipe	1	do
9	Conduit reducers 50 mm x 25 mm	1	do
10	Conduit bend for 25 mm Conduit	1	do
11	Lock nut for 25 mm conduit	1	do
12	Conduit bushing for 25 mm Conduit	1	do
13	wooden plugs	1	do
14	Conduit saddles: 50 mm	25	do
	25 mm	4	do
15	IC Main board of size 25cm x 30cm	8	do
16	Kit-kat 32 A capacity	1	No
17	Neutral link	1	do
18	Aerial fuse 32A capacity	1	do
19	stay wire 7/10 SWG	1	do
20	stay bow	10	m
21	stay rod with bolts & stay buckle	(1)	(kg)
22	Stay insulator	1	No.
23	Cement	1	do.
24	Sand	1	do
25	Catenary wire	1	bag
26	clips 31mm	5	bags
27	Sundries to complete the job	3	kg
		1	packet
	Storage & transportation charges	Total →	
	Labour Charges	5% →	
	Contingencies	10% →	
	Electrical inspection fee	1% →	
	1φ, 25A, 240V, 50 Hz Energy meter	→	
	Grand Total	→	
	Say	→	
6. (a)	The OH line or cable connecting the supplier's distributing line to the consumer's premises is called service main or service line or service connection.		— (1) m
	Methods of installation of service lines → OH service lines & UG cable service lines		— (1)

Question Number	Solution	Marks Allocated
	<p>Various methods used for installation of OH service lines are:</p> <ul style="list-style-type: none"> → for high roof building → for low roof or single storeyed building → weather proof cable method → Use of junction or joint box 	2
6.(b)	<p>Two methods of installation of OH service lines based on the prevailing conditions of building</p> <ul style="list-style-type: none"> → for high roof building → for low roof or single storeyed building 	3 3
6.(c)	<p><u>Single Line Diagram</u> : Assumed $\eta_m = 0.85$ & $PF = 0.8$ lag</p>  <p>Full load current = $\frac{10 \times 735.5}{\sqrt{3} \times 415 \times 0.8 \times 0.85} = 15.05 \text{ A}$</p> <p>Starting current = $1.5 \times 15.05 = 22.6 \text{ A}$</p> <p>Hence 3 core, PVC, 1100V grade, 6 mm^2 aluminium cond. cable of current carrying capacity of 24A may be used.</p> <p><u>Length of 25mm HG Rigid Conduit:</u></p> <p>From meter board to main board = 0.3m From main board to motor switch = 22.5m (mounted on control board) Total = 22.8m ; wastage 10% = 2.3m \therefore Total = 25.1m = 25m (say)</p> <p><u>Length of 31mm HG Conduit:</u></p> <p>From motor starter to ground = 1.5m Below ground level = 0.2m ; Along ground up to foundation = 1.0m Up to top of motor foundation = 0.4m ; Total = 3.1m wastage 10% = 0.31m ; \therefore Total = 3.41m = 3.5m (say)</p>	2 1 1

Question Number	Solution	Marks Allocated
	<p>Length of 25mm flexible Conduit required for connecting motor switch to motor starter = 0.25m Length of 31mm flexible Conduit required for connecting heavy gauge conduit to motor = 1m Length of 3 core, 1100V grade, 1/2.80 mm (6mm²) aluminium cond pvc cable:</p> <p>1 length from meter board to main board = 0.3m 1 length from main board to motor switch = 22.5m 1 length from motor switch to motor starter = 0.25m 2 lengths from motor starter to motor terminal box = 8.2m Total length = 31.25m ; wastage & for connections 10% = 3.13m ∴ Total = 34.38m = 35m (say)</p> <p><u>Length of Earth wire</u>: According to IE Rules, two separate earth electrodes will be provided for earthing purpose. From the table for size of earth wire, for 10HP motor 8 SWG GI wire will be required as earth wire. Length of earth wire required = 2 × (length of conduit including length of flexible conduit) = 2 × (25 + 3.5 + 0.25 + 1) = 59.5m = 60m (say) or 6 kg.</p> <p>Estimate on the basis of item wise rates</p>	<p>10m</p> <p>10m</p> <p>3m</p> <p>6m</p>
7. (a)	<p style="text-align: center;"><u>Module - 4</u></p> <p>Write any 7 points</p> <ul style="list-style-type: none"> * Proper jumper should be used wherever required * Pole steps should be provided in the towers for the lineman to climb the pole * Guard wires should be provided where essential * The cond should be tightened on the insulator properly with binding wires * The joints of the cond should be mechanically strong in proper sleeves * One-sixth of the pole length should be properly buried and rammed in the soil * Anti-climbing device & danger plate or caution notice should be fixed on each pole. * Permissible spacing b/w the cond should be maintained through out the lines. 	6m

Question Number	Solution	Marks Allocated
	<p>* The clearance of cond from ground & adjoining should be according to IER 77, 78, 79 & 80.</p> <p>* All metallic parts, line components except main line Cond should be earthed properly according to IER 90.</p>	
7(b)	Explanation of each term x 2 m	6 m
7(c)	<p><u>Earthing of transmission line supports using pipe earthing</u></p>	3 m
	<p>Explanation</p>	5 m

Question Number	Solution	Marks Allocated
8(a)	<p><u>Repairing of OH ACSP to Conds</u> → Repair sleeves are employed for repairing of ACSP or all Aluminium Conds which have sustained surface damage causing a few of aluminium strands to be damaged or broken.</p> <p><u>Joining of OH ACSP to Conds</u> → The use of mid span tension joints is a subject on which there are different opinions. Some engineers do not use mid-span joints except for repairs while others do use joints on new construction.</p> <p><u>How jointing on repairing is done</u></p> <p>↳ splice joints, Britannia joints, married joint, sleeve joint, compression joint</p>	<p>① m</p> <p>① m</p> <p>② m (A)</p> <p>⑥ m</p>
8(b)	<p><u>Explanation of each term</u> × ③ m</p>	<p>③ m</p>
8(c)	<p><u>Sketch</u> → <u>earthing & Staying</u></p>	<p>③ m</p>
<p><u>List of materials Required</u></p>		
<p><u>Sl.no</u></p>	<p><u>Description of material with complete specifications</u></p> <p>(A) <u>Earthing (pipe earthing)</u></p>	<p><u>Quantity required</u></p> <p><u>Qty</u> <u>unit</u></p>
<p>1.</p>	<p>25mm dia GI pipe</p>	<p>2.5 m</p>
<p>2.</p>	<p>19mm dia GI pipe</p>	<p>1.5 m</p>
<p>3.</p>	<p>12mm dia GI Pipe</p>	<p>4.0 m</p>

Question Number	Solution	Marks Allocated
	<p>4. GI wire 6 SW G → 12 do (1.2) kg 5. GI lugs → 2 nos. 6. 10mm dia, 32mm long GI bolts & nuts → 2 nos 7. 16mm dia, 40mm long GI bolts, nuts & washers → 2 nos 8. 12mm dia GI bends → 1 do 9. 30cm square cast iron frame → 1 no 10. 30cm square cast iron covers → 1 do 11. Funnel with wire mesh → 1 do 12. Charcoal → 10 kg 13. Common salt → 10 do 14. Cement concrete 1:4:8 → 0.15 m³</p>	<p>3 m</p>
	<p><u>(B) Staying</u></p> <p>1. MS anchor plate 45cm x 45cm x 6.0cm → 1 no (Not galvanised) 2. MS stay rod 16mm dia and 2.42m long → 1 dozen 3. Stay bow made of MS rod 12mm dia → 1 do 4. Stay insular → 1 do 5. Stay wire (7/8 SW G GI wire) → 7.5m (4.5 kg) 6. Stay clamp → 1 no 7. 16mm dia, 76mm long bolts, nuts for fixing ↳ 2 do 8. MS thimbles → 2 do 9. Cement concrete 1:4:8 → 0.2 m³</p>	<p>2 m</p>
	<p style="text-align: center;"><u>Module - 5</u></p> <p>9(a) <u>Equipment available in a SS</u></p> <ul style="list-style-type: none"> ↳ Main Bus Bars ↳ Reactors ↳ Station insulators ↳ Switch gear <ul style="list-style-type: none"> ↳ Air break switches ↳ oil switches ↳ Isolators ↳ Load interrupter switches ↳ earthing switch ↳ fuses ↳ Circuit Breakers ↳ Power T/Fs ↳ Protective relays ↳ Instrument T/Fs <ul style="list-style-type: none"> ↳ current T/Fs (CTs) ↳ Potential T/Fs (PTs) <p>9(b) <u>Substation Auxiliary supply</u></p>	<p>5 m</p> <p>5 m</p>

Question Number	Solution	Marks Allocated								
9(C)	<p><u>List of materials required for installation of 400 kVA indoor type 11/0.4/33 kV T/F</u></p>									
	<table border="1"> <thead> <tr> <th data-bbox="240 365 379 442"><u>Sl. No</u></th> <th data-bbox="384 365 1098 494"><u>Description of material with complete specifications</u></th> <th colspan="2" data-bbox="1102 365 1337 442"><u>Quantity Required</u></th> </tr> <tr> <td></td> <td></td> <th data-bbox="1102 449 1177 494"><u>Qty</u></th> <th data-bbox="1182 449 1337 494"><u>Unit</u></th> </tr> </thead> </table>	<u>Sl. No</u>	<u>Description of material with complete specifications</u>	<u>Quantity Required</u>				<u>Qty</u>	<u>Unit</u>	
<u>Sl. No</u>	<u>Description of material with complete specifications</u>	<u>Quantity Required</u>								
		<u>Qty</u>	<u>Unit</u>							
1)	400 kVA, 11/0.4/33 kV, 3 ϕ , 4 wire 50 Hz indoor type T/F complete with all accessories & first filling of oil } → 1 NO									
2)	XLPE insulated aluminium cond 10mm ² 3 core heavy duty 11KV grade cable } → 30 m									
3)	11KV end terminal box complete with jointing materials for XLPE cable (outdoor type) } → 1 NO	(5m)								
4)	11KV end terminal box complete with jointing materials for XLPE cable (indoor type) } → 1 NO									
5)	GI pipe 76mm dia heavy gauge } → 5 m									
6)	clamps for fixing cable pipe (GI) & end boxes } → 8 NOS									
7)	Indoor type oil CB, 11KV with 50/5A CTs for metering arrangement instrumentation protection equipment, capacity 400 kVA rupturing capacity 200MVA } → 1 NO									
8)	Earthing for OCB } → 2 sets									
9)	sand } → 30 m ³									
10)	Bricks (2nd class) } → 5000 NOS									
11)	Cement slabs for covering trenches 33m long } → 100 do									
12)	Empire tape } → 20 Rolls									
13)	HT tape } → 3 do									
14)	Foundation for 400 kVA T/F (Cement, sand, mortar etc) } → 1 NO									
15)	Earthing for T/F } → 2 do.									
16)	oil CB, 3 ϕ , 415V, 800 A, 15 MVA rupturing capacity equipped with (i) first filling of oil (ii) 500/5 A, 15 VA CTs (iii) overload Trip coils (iv) adjustable dashpot time lags & under volt release } → 1 do									

Question Number	Solution	Marks Allocated																																																																								
	17) LT cubicle board 1.5m x 1.5m x 2m pedestal type with locking arrangement for bus-bus connection to OCB at item no 16. → 1 do 18) LT cable, 3 1/2 core, 240mm ² (2 lengths of 15m each) → 30m 19) Aluminium lugs assorted for phase conductors & neutral conductors → 16 Nos 20) Earthing of LT panel → 2 do 21) Sundries to complete the job such as Bolts & Nuts & other petty items (LS provision).	(5) m (6) m																																																																								
10(a)	each term x (2) m																																																																									
10(b)	132/33KV substation having 2x40MVA T/Fs																																																																									
	<table border="1"> <thead> <tr> <th data-bbox="263 952 391 1009">Sl. No</th> <th data-bbox="502 941 758 1009">Equipments</th> <th data-bbox="1093 918 1332 1054">Quantity Required Qty unit</th> </tr> </thead> <tbody> <tr> <td data-bbox="263 1054 295 1111">1)</td> <td data-bbox="430 1043 542 1099"><u>CBs</u></td> <td></td> </tr> <tr> <td></td> <td data-bbox="446 1099 598 1145">132KV</td> <td data-bbox="1125 1077 1316 1122">5 Nos</td> </tr> <tr> <td></td> <td data-bbox="470 1145 606 1190">33KV</td> <td data-bbox="1141 1122 1316 1168">11 do</td> </tr> <tr> <td data-bbox="263 1202 295 1258">2)</td> <td data-bbox="367 1190 726 1258"><u>Line isolators</u></td> <td></td> </tr> <tr> <td></td> <td data-bbox="510 1258 654 1304">132KV</td> <td data-bbox="1173 1190 1300 1236">2 do</td> </tr> <tr> <td></td> <td data-bbox="534 1304 654 1349">33KV</td> <td data-bbox="1204 1236 1324 1281">10 do</td> </tr> <tr> <td data-bbox="263 1360 295 1417">3)</td> <td data-bbox="383 1349 678 1417"><u>Bus Isolators</u></td> <td></td> </tr> <tr> <td></td> <td data-bbox="494 1417 654 1462">132KV</td> <td data-bbox="1204 1326 1316 1372">8 do</td> </tr> <tr> <td></td> <td data-bbox="518 1462 654 1508">33KV</td> <td data-bbox="1204 1372 1340 1417">15 do</td> </tr> <tr> <td data-bbox="263 1496 295 1553">4)</td> <td data-bbox="327 1485 877 1553">Tendron isolators 132KV</td> <td data-bbox="1220 1417 1340 1462">4 do</td> </tr> <tr> <td data-bbox="263 1553 295 1610">5)</td> <td data-bbox="335 1553 662 1598"><u>CTs</u> 132KV</td> <td data-bbox="1189 1462 1340 1508">12 do</td> </tr> <tr> <td></td> <td data-bbox="518 1598 662 1644">33KV</td> <td data-bbox="1204 1508 1332 1553">33 do</td> </tr> <tr> <td data-bbox="263 1655 295 1712">6)</td> <td data-bbox="526 1644 798 1689">132KV CVT</td> <td data-bbox="1220 1553 1332 1598">9 do</td> </tr> <tr> <td></td> <td data-bbox="534 1689 758 1735">33KV PT</td> <td data-bbox="1204 1598 1332 1644">6 do</td> </tr> <tr> <td data-bbox="263 1735 295 1791">7)</td> <td data-bbox="255 1712 837 1791"><u>LA (Lightning Arrestor)</u></td> <td></td> </tr> <tr> <td></td> <td data-bbox="406 1791 574 1837">132KV</td> <td data-bbox="1204 1712 1332 1757">12 do</td> </tr> <tr> <td></td> <td data-bbox="422 1837 574 1882">33KV</td> <td data-bbox="1236 1757 1348 1803">12 do</td> </tr> <tr> <td data-bbox="263 1882 295 1939">8)</td> <td data-bbox="311 1871 622 1939"><u>Post insulator</u></td> <td data-bbox="1236 1825 1348 1871">92 do</td> </tr> <tr> <td data-bbox="263 1939 295 1995">9)</td> <td data-bbox="335 1927 893 1995"><u>T/Fs</u> 132/33KV, 40MVA</td> <td data-bbox="1236 1893 1348 1939">2 Nos</td> </tr> <tr> <td></td> <td data-bbox="343 1995 790 2052">33/4KV, 250 KVA</td> <td data-bbox="1252 1939 1348 1984">1 NO</td> </tr> <tr> <td data-bbox="263 2052 295 2109">10)</td> <td data-bbox="311 2029 1125 2097"><u>Control panel</u> T/F Control & Relay panel</td> <td data-bbox="1252 1984 1348 2029">2 NO</td> </tr> <tr> <td></td> <td data-bbox="614 2097 813 2143">B/c panel</td> <td data-bbox="1268 2029 1348 2075">1 NO</td> </tr> <tr> <td></td> <td data-bbox="614 2097 1029 2165">Double feeder panel</td> <td data-bbox="1268 2075 1348 2120">1 NO</td> </tr> </tbody> </table>	Sl. No	Equipments	Quantity Required Qty unit	1)	<u>CBs</u>			132KV	5 Nos		33KV	11 do	2)	<u>Line isolators</u>			132KV	2 do		33KV	10 do	3)	<u>Bus Isolators</u>			132KV	8 do		33KV	15 do	4)	Tendron isolators 132KV	4 do	5)	<u>CTs</u> 132KV	12 do		33KV	33 do	6)	132KV CVT	9 do		33KV PT	6 do	7)	<u>LA (Lightning Arrestor)</u>			132KV	12 do		33KV	12 do	8)	<u>Post insulator</u>	92 do	9)	<u>T/Fs</u> 132/33KV, 40MVA	2 Nos		33/4KV, 250 KVA	1 NO	10)	<u>Control panel</u> T/F Control & Relay panel	2 NO		B/c panel	1 NO		Double feeder panel	1 NO	(2) m
Sl. No	Equipments	Quantity Required Qty unit																																																																								
1)	<u>CBs</u>																																																																									
	132KV	5 Nos																																																																								
	33KV	11 do																																																																								
2)	<u>Line isolators</u>																																																																									
	132KV	2 do																																																																								
	33KV	10 do																																																																								
3)	<u>Bus Isolators</u>																																																																									
	132KV	8 do																																																																								
	33KV	15 do																																																																								
4)	Tendron isolators 132KV	4 do																																																																								
5)	<u>CTs</u> 132KV	12 do																																																																								
	33KV	33 do																																																																								
6)	132KV CVT	9 do																																																																								
	33KV PT	6 do																																																																								
7)	<u>LA (Lightning Arrestor)</u>																																																																									
	132KV	12 do																																																																								
	33KV	12 do																																																																								
8)	<u>Post insulator</u>	92 do																																																																								
9)	<u>T/Fs</u> 132/33KV, 40MVA	2 Nos																																																																								
	33/4KV, 250 KVA	1 NO																																																																								
10)	<u>Control panel</u> T/F Control & Relay panel	2 NO																																																																								
	B/c panel	1 NO																																																																								
	Double feeder panel	1 NO																																																																								

Question Number	Solution	Marks Allocated
	<p>Single line diagram of 132/33kV SS</p>	<p>4 M</p>
	<p>10) Distance protection panel ————— 3 nos 33kV tripple feeder panel ————— 3 nos</p> <p>11) U/F Relay panel ————— 1 do</p> <p>12) Energy meter 0.2 acc cls (ABT) ————— 1 do</p>	<p>1 do</p>

Question Number	Solution	Marks Allocated
	13) Control & power cable → LS provision 14) structures → 60 MT 15) DC equipments (protection & Conn.) — 1 set 16) ACDB — 1 NO 17) Bus Bar & Insulator — 1 set 18) S/S & Control Room Lighting → LS provision 19) Earthmat & earthing → do 20) Firefighting equipment → do 21) Boundary wall, fencing, control room building, store shed etc } — do 22) Land (subject to actual) → do	} (2) m (6) m
10 (c)	purposes of substation earthing s/m → safety of operational & maintenance staff. → Discharge of electrical charges to ground → Grounding of OH shielding wires → Electromagnetic Interference.	(6) m

"APPROVED"
Bunni
 Registrar (Evaluation)
 Visvesvaraya Technological University
 BELAGAVI - 590018